

Mechanical Systems for Deep Energy Retrofits in Multi-Family



Galen Staengl, PE, LEED BD+C CHPC

Agenda

- Retrofit relevance
- The problem
- Electrification - reinventing fire?
- The big idea (solution approach)
- System approaches
- Case Study (Colonial II)
- Mechanical Pod Development

The Importance of Deep Energy Retrofits

- Total Housing Units in the US: ~ 145,000,000
- New Housing Units: ~ 1%/year

Deep Energy Retrofits are key to reducing the carbon intensity of the housing sector.

Residential delivered energy intensity
million British thermal units per household






Figure ES3. Base Case Energy Use



The Opportunity



U.S. Building Stock Characterization Study

A National Typology for Decarbonizing U.S. Buildings

Janet Reyna,¹ Eric Wilson,¹ Andrew Parker,¹ Aven Satre-Meloy,²
Amy Egerter,³ Carlo Bianchi,¹ Marlena Praprost,¹
Andrew Speake,¹ Lixi Liu,¹ Ry Horsey,¹ Matthew Dahlhausen,¹
Christopher CaraDonna,¹ and Stacey Rothgeb¹

1 National Renewable Energy Laboratory

2 Lawrence Berkeley National Laboratory

3 Rocky Mountain Institute

**NREL is a national laboratory of the U.S. Department of Energy
Office of Energy Efficiency & Renewable Energy
Operated by the Alliance for Sustainable Energy, LLC**

This report is available at no cost from the National Renewable Energy Laboratory (NREL) at www.nrel.gov/publications.

Contract No. DE-AC36-08GO28308

Technical Report
NREL/TP-5500-83063
Revised July 2022

Residential Segments - Mixed-Humid




Figure 10. Residential Mixed-Humid typology segments

Residential Segments - Cold & Very Cold




Figure 7. Residential Cold/Very-Cold typology segments

Residential Segments - Hot-Dry & Mixed-Dry




Figure 16. Residential Hot-Dry/Mixed-Dry typology segments

Residential Segments - Hot-Humid





Figure 19. Residential Hot-Humid typology segments





Project Optimization



Apply Passive Building Principles to Comfort and Hot Water

The “Cost Effective” Deep Energy Retrofit



Courtesy of Monty Python

The Holy Grail of Building Energy Savings

Objectives:


- Dramatic Building Energy Savings (>50%)
- Retrofit-in-place
- Electrification

Challenges:


- Limitations on exterior insulation
- Electrical service capacity
- Equipment availability
- COST




Insulate the Envelope



Exterior



Interior



Electrification – Space Heat / Cool

Air-to-Air



Air-to-Water



Water-to-Air



Water-to-Water




Electrification - DHW



System Approach

Can we penetrate the exterior envelope?

- Historic Envelope?
- Lot Line Issues?




System Approach

If we can't penetrate the exterior: Can we fit ductwork in the corridor?

YES

- Ventilation Air from Rooftop DOAS/ERV
- Space Conditioning:
 - Water source heat pumps?
 - Hydronic fan coils?
 - VRF?
- Heat Pump Based Central Plant:
 - Air Source Heat Pumps?
 - Geothermal?
 - Solar HW?
 - VRF?



System Approach


4-pipe or 2-pipe hydronic system

Advantages

- High Efficiency
- Opportunities for heat recovery to domestic hot water in central DHW system

Disadvantages

- Cost of piping is high if not already there



System Approach


Water-source heat pumps

Advantages

- Neutral water piped through the building. Can re-use existing heating water piping
- Can capture waste heat for domestic hot water heating in a central DHW plant

Disadvantages

- Compressor in every apartment
- Lower COP if using air-to-water heat pumps in central plant



System Approach

Ground / Solar-source heat pumps



Advantages

- Very low energy use
- Can be integrated with solar
- Lower maintenance costs
- Heat recovery to DHW possible

Disadvantages

- Requires real estate for geothermal wells
- High cost, but lower now with tax credits available, that apply to full HVAC system
- Compressor in every apartment

Ground Loop Vertical Wells



System Approach


VRF

Advantages

- Less costly than hydronic

Disadvantages

- Requires refrigerant line-sets to be run throughout the building
- High potential refrigerant loss, with high global warming potential
- High embodied carbon content of refrigerant
- High maintenance costs




HW Heater Sizing

HW **heaters** are oversized based on outdated assumptions for fixture flow, and occupant diversity.


Example:

- 60 occupant apartment building
- Standard ASHRAE assumptions:
 - 210 gallons storage
 - 82,000 BTU/HR heater
- Adjusted for modern fixtures and Diversity:
 - 110 gallons storage
 - 41,000 BTU/HR heater




HW Consumption Design Data

- Know your population
- Use measured consumption data if possible



HW Consumption Measured Data



HW Consumption Study for 95 unit Senior Housing apartment building.

	Range (GPM)	Duration (Minutes/day)	%	Cumulative Flow (Gallons)
Low Draw	0-3	1152	80%	1,400
Med Draw	3-6	230	16%	280
High Draw	6-9	43	3%	53
Peak Draw	9+	14	1%	18

Total Gallons per day	1,750
-----------------------	-------

24 hour monitoring study. Courtesy of IntelliHot

Water Demand Calculator (WDC v2.1)

PROJECT NAME :

Multi-Family Building

Click for Drop-down Menu →

Total Number of Apartments in the Building →

95

Total Apartments in this Calculation →

95

Monday, October 11, 2021

4:49 PM

FIXTURE GROUPS		FIXTURE	ENTER TOTAL NUMBER OF FIXTURES	PROBABILITY OF USE (%)	ENTER FIXTURE FLOW RATE (GPM)	MAXIMUM RECOMMENDED FIXTURE FLOW RATE (GPM)
Bathroom Fixtures	1	Bathtub (no Shower)	0	0.38	5.5	5.5
	2	Bidet	0	0.55	2.0	2.0
	3	Combination Bath/Shower	0	1.41	5.5	5.5
	4	Faucet, Lavatory	95	1.11	1.5	1.5
	5	Shower, per head (no Bathtub)	95	0.94	2.0	2.0
	6	Water Closet, 1.28 GPF Gravity Tank	95	0.55	3.0	3.0
Kitchen Fixtures	7	Dishwasher	0	0.32	1.3	1.3
	8	Faucet, Kitchen Sink	95	1.11	2.2	2.2
Laundry Room Fixtures	9	Clothes Washer	5	1.33	3.5	3.5
	10	Faucet, Laundry	0	1.11	2.0	2.0
Bar/Prep Fixtures	11	Faucet, Bar Sink	0	1.11	1.5	1.5
Other Fixtures	12	Fixture 1	0	0.00	0.0	6.0
	13	Fixture 2	0	0.00	0.0	6.0
	14	Fixture 3	0	0.00	0.0	6.0

COMPUTED RESULTS FOR PEAK PERIOD CONDITIONS

Total No. of Fixtures in Calculation
n = 385

99th Percentile Demand Flow
Q = 17.0 GPM

Hunter Number
H(n,p) = 3.59

Stagnation Probability
Pr[Zero Demand] = 3%

DOWNLOAD RESULT

RESET WDC

↓ Select Units for Water Demand ↓

GPM

LPM

LPS

RUN WDC

Electrification

- Benefits

- Carbon reduction
- Safety
- IAQ
- Local Air Quality

- Barriers

- Heating loads
- Electrical Infrastructure
- Relative cost of Gas / Electricity
- Immature heat pump market in the US
- Outside design temperature?

Colonial II

A Net-Zero Energy Retrofit




Colonial II



Pre- Retrofit EUI: 117 kBTU/sqft!

Masonry Construction:
No Wall Insulation



Colonial II



Ancient Gas Boilers:
2 x 2.6 MMBTU/hr



Gas HW Heaters:
2 x 300kBTU/hr

Colonial II

New Windows




New Air Barrier

New Exterior Insulation



Colonial II



All-In One Heat Pump

Simple Ductwork

1
M2.01 | M4.00
UNIT TYPE A MECHANICAL DUCTWORK PLAN
SCALE: 1/4" = 1'-0"

~1,000,000 BTU/HR OF HEAT PUMP INSTALLED

Interior Retrofit 99 to 74 Apartments

Colonial II





~0.9 W/SQFT

ASE 85%


TRE 67%



INTEGRATED HEAT
PUMP WITH ERV



Colonial II



Colonial II

All-in One WS
Heat Pump




Geothermal
Manifold

Colonial II



Solar Field Above Well Field



Vertical Geothermal Well Field

Colonial II



- New electrical service – 3000 A / 208 V / 3 Phase
- Old electrical service - 1400 A / 208 V / 3 Phase



Required New Fire
Pump, and Solar Field
Required Electrical
Service Upgrade


Colonial II

- HW consumption of building population measured prior to retrofit
- Pre-retrofit condition:
 - 99 Apartments
 - Low flow fixtures




Measured HW Consumption: Courtesy of Klein and Skinner

Colonial II




HEAT PUMP
CAPACITY ~12% OF
ORIGINAL GAS
CAPACITY!

Colonial II



Mechanical Pod Development



Hydronic piping run behind cladding

Air to water HP and fluid cooler

DHW generated from rooftop equipment and distributed through existing piping if in good condition [Heat Recovery]


Exhaust ←

Fresh Air →

ERV

WS HP

Indoor Pod



TKF



Thank You

Galen Staengl, PE, LEED BD+C CHPC

Staengl Engineering

1747 Allied St.

Suite L

Charlottesville, VA 22903

(434)295-8105

gstaengl@staenglengineering.com



Photo Credit: Ezra Staengl

STAENGL
ENGINEERING

