

Update on Phius' Retrofit Standard

Graham S. Wright, Al Mitchell



Overview

- About the Standard
- Performance Calculation Examples





Every building supports the health of people and the planet.





Every building supports the health of:

People

&

Planet





Every building supports the health of:

People

&

Planet

• Climate / GHG / CO₂ / Carbon



Every building supports the health of:

People

&

Let's focus on just this crisis for now.

Planet

• Climate / GHG / CO₂ / Carbon





Every building supports the health of:

People

&

Planet

• Climate / GHG / CO₂ / Carbon



I recently learned that waste heat will boil the oceans in about 400 years. Sabine Hossenfelder · 390K views · 3 weeks ago

Sabine Hossenfelder



Climate Action

Every building supports the health of:

People

&

Planet

• Climate / GHG / CO_2 / Carbon \implies Decarbonization





Vision Again

Every building supports the health of:

People

Absolute Zero - no emissions ever happen in the supply chain or building life.*

No resort to carbon offsets

&

Planet

• Climate / GHG / CO_2 / Carbon \implies Decarbonization



Every building supports the health of:

People

- Shelter (it's what buildings do for people)
- & Health per se

Planet





From Vision to Action – Things to do for existing buildings

Every building supports the health of:

People

- Shelter Robust, Resilient Weatherization & Fortification versus site hazards
- Health \implies Removing-unhealthy-stuff-ification

Planet

Climate / GHG / CO₂ / Carbon → Decarbonization

A way to describe the concept quickly

Resilience (or weatherization)

+ Health

+ Decarbonization



Measures such as:

Resilience | Air sealing, insulation, seismic, PV, batteries...

+

Health | Radon, Carbon monoxide, mold...

+

Decarbonization | Electrification, community solar, low-carbon choices...





+Quality Assurance Process

To ensure the requirements are met and that benefits persist.





Circling back to Decarbonization

- Absolute Zero can't yet be done so, then what? Meaning what now?
- What about operational vs. embodied carbon?






Decarbonization

An Idea 🍹

- Design as if there's a cost of carbon
- Minimize total cost, total life cycle cost





Decarbonization

An Idea 🍹


- Design as if there's a cost of carbon
- Minimize total cost, total life cycle cost

Dear Funder,

If there were a carbon tax, I could justify doing <this much> to decarbonize my building; would you like to fund any of that in the name of ESG or the like?

Regards,

Owner





Decarbonization

Cost Metric = Sum of these annualized costs:

- Direct energy cost. E.g. site kWh * \$/kWh = \$
- Direct building retrofit measures cost (material & labor) including building-level electrification cost. E.g. ft3 of stuff * \$/ft3 = \$
- Cost of carbon -- upfront/embodied. CO2e kg * \$/kg = \$
- Cost of carbon operating. CO2e kg * \$/kg = \$
- Energy system transition cost. E.g. new solar + storage. \$/MW * MW = \$

Names

Begin thinking about which you'd prefer, will poll in a bit...

- ADORB cost Annualized Decarbonization Of Retrofitted Buildings cost
- FCALC cost Full Cost Accounted Life Cycle cost



Retrofit Planning Framed as an Optimization


Every building supports the health of:

People

- Shelter \rightarrow Robust, Resilient Weatherization & Fortification.
- Health \rightarrow Removing-unhealthy-stuff-ification.

Planet

- Climate / GHG / CO_2 / Carbon \rightarrow Decarbonization
- Minimize ADORB / FCALC cost



More Practical Approach for Now


Every building supports the health of:

People

- Shelter → Robust, Resilient Weatherization & Fortification.
- Health \rightarrow Removing-unhealthy-stuff-ification.


Planet

- Climate / GHG / CO2 / Carbon \rightarrow Decarbonization.
- Minimize ADORB / FCALC cost ≤ Baseline
- + Additional decarbonization effort op & embodied



ADORB / FCALC

More about some of these later




One Question Poll: ADORB or FCALC?

Next Up: Resilience



Building / campus / block scale

- Resilience from the grid
- Outage conditions



Utility scale

- Resilience for the grid
- Normal operation



Resilience Performance Protocol

- Simulate seven-day outages, in extreme weather.
- Whole building remains habitable, not just a protected zone.
- On-site PV and batteries provide limited power.
- Assume full design occupancy for residential.
- Reduced ventilation rate 5 cfm/person.



Resilience Performance Protocol & Criteria

- Simulate seven-day outages, in extreme weather.
- Whole building remains habitable, not just a protected zone.
- On-site PV and batteries provide limited power.
- Assume full design occupancy for residential.
- Reduced ventilation rate 5 cfm/person.

Winter Resilience Criteria

- Zero hours below 35°F
- Limited degree-hours

≤ 216 SET-hours*, base 54°F

(*similar to LEED pilot credit)



Resilience Performance Protocol & Criteria

• Same as Winter

- Simulate seven-day outages, in extreme weather.
- Whole building remains habitable, not just a protected zone.
- On-site PV and batteries provide limited power.
- Assume full design occupancy for residential.
- Reduced ventilation rate 5 cfm/person.

Summer Resilience Criteria

- Zero hours of Heat Index in Danger
- Limited hours of Heat Index in Extreme Caution



O Health and Hazards

EPA

- 1. Asbestos
- 2. Belowground contaminants (except radon)
- 3. Building products/material emissions
- Carbon monoxide and other combustion appliance emissions (nitrogen oxides, VOCs and particulates)
- 5. Environmental tobacco smoke
- 6. Garage air pollutants (CO, benzene and other VOCs)
- 7. Lead
- 8. Moisture (mold and other biologicals)
- 9. Pests
- 10. Polychlorinated biphenyls

- 11. Radon
- 12. Wood smoke and other solid fuel emissions
- 13. Heating, ventilating and air conditioning (HVAC) equipment
- 14. Combustion safety, vented combustion appliances
- 15. Combustion safety, unvented combustion appliances
- 16. Source or local exhaust ventilation
- 17. Whole-dwelling ventilation for distributed contaminant sources
- 18. Home safety
- 19. Protecting IAQ during construction
- 20. Jobsite safety


FEMA, IBHS

SEISMIC FLOOD, TSUNAMI HAIL WIND ICE DAMS, SNOW LOAD WILDFIRE


Break for questions

Next Up: Quality Assurance

Q + Quality Assurance Process



Q + Quality Assurance Process



O Concepts for Requirements

- 1. A quality assurance process covers all phases of the retrofit.
- 2. The existing building is assessed as to suitability for retrofit, energy performance, and risks to indoor air quality and from site hazards.
- 3. Resilience to grid outages summer and winter buildings remain habitable and critical electrical loads are covered.
- 4. Fix any existing deficiencies that pose risks to indoor air quality.
- 5. Life cycle calculations are done using a full-cost accounting metric called ADORB / FCALC that includes a cost of carbon.
- 6. Direct emissions cease soon.
- 7. Project cost data and post-retrofit measured energy performance are reported.




O Concepts for Requirements

- 1. A quality assurance process covers all phases of the retrofit.
- 2. The existing building is assessed as to suitability for retrofit, energy performance, and risks to indoor air quality and from site hazards.
- **3.** Resilience to grid outages summer and winter buildings remain habitable and critical electrical loads are covered.
- 4. Fix any existing deficiencies that pose risks to indoor air quality.
- 5. Life cycle calculations are done using a full-cost accounting metric called ADORB / FCALC that includes a cost of carbon.
- 6. Direct emissions cease soon.
- 7. Project cost data and post-retrofit measured energy performance are reported.



O Concepts for Requirements

- 1. A quality assurance process covers all phases of the retrofit.
- 2. The existing building is assessed as to suitability for retrofit, energy performance, and risks to indoor air quality and from site hazards.
- **3.** Resilience to grid outages summer and winter buildings remain habitable and critical electrical loads are covered.
- 4. Fix any existing deficiencies that pose risks to indoor air quality.
- 5. Life cycle calculations are done using a full-cost accounting metric called ADORB / FCALC that includes a cost of carbon.
- 6. Direct emissions cease soon.
- 7. Project cost data and post-retrofit measured energy performance are reported.



Outline of the Standard

Additions are within

existing building

scope, if smaller than the

Foreword

- 1. Purpose
- 2. Scope -
- 3. Definitions
- 4. Process
- 5. Mitigate Existing Deficiencies
- 6. Performance Requirements
- 7. Monitoring, M&V Requirements

Including just the normative appendices

- A ADORB Calculation method
- T-0 Program Plan Outline
- T-1 CFR/OPR Outline
- T-2 Commissioning Plan Outline
- T-6 Commissioning Report Outline
- T-7 Ongoing Commissioning Plan Outline
- T-8 Ongoing Commissioning Report Outline



The Standard Document

Name: Phius/TBD EB1-2023

- Written in code-mandatory language. •
- All calculation protocol spelled out, for • requirements on modeled performance.

Roles:

- Owner ______
- •
- Commissioning Provider •
- Verification & Testing Providers

The Certification Program


Name: Phius REVIVE Pilot (for now)

- Our certification to the standard.
- Maintain open-source calculation engine. •

Corresponding Roles for our certification to the standard:

- Owner
- Phius
- Phius Raters & Verifiers

4 | Quality Assurance Process



Use of Commissioning for Certification / Enforcement

ASHRAE Cx standards are written for the benefit of the <u>Owner</u>, to fulfill <u>Owner's</u> Project Requirements (OPR).


Adaptations for use in Certification / Enforcement:

- Most of the requirements in the CFR / OPR are those of this standard.
- Documentation deliverables go to both Owner and Authority.
- Gates for Acceptance & decision-to-proceed require concurrence of Owner and Authority.



4 | Quality Assurance Process

Compliance is documented



Owner Input

A la carte electives listed in the standard.

- These are additional improvements beyond the required minimums.
- If the owner opts for any of these, they are subject to the QA process.

Other, such as:

- Regulatory, i.e., correct this code violation X.
- Functional requirements, especially in the case of additions
 - e.g., Kitchen needs cooktop but not an oven, need an ADA door here...
- Preferred vendors



Questions so far?

Next Up: Actual Requirements

5 Mitigate Existing Deficiencies6 Performance Requirements7 Monitoring, M&V Requirements

5 | Mitigate Existing Deficiencies

- **5.1** Indoor Air Quality and Moisture Risk Mitigation
- **5.2** Hazard Mitigation



5 | Mitigate Existing Deficiencies

- 5.1 Indoor Air Quality and Moisture Risk Mitigation
 - All Minimum Actions in the EPA Energy Savings Plus Health Guidelines.
 - Any EPA Expanded Actions elected by the Owner.
 - New additions comply with Energy Star Residential New Construction.
 - Phius Certification Guidebook Appendix B.
- 5.2 Hazard Mitigation



5 | Mitigate Existing Deficiencies

- 5.1 Indoor Air Quality and Moisture Risk Mitigation
- 5.2 Hazard Mitigation minimum actions (as applicable)
 - Seismic performance grade B- or higher (a la FEMA P-50).
 - Electrical / mechanical protected from **flood** per FEMA or IBHS.
 - Hail Roof mounted PV meets IBHS FORTIFIED[™] Hail Supplement.
 - Structural/Wind No unreinforced dry-stack foundations. FORTIFIED Roof.
 - Mitigate any ice dams.
 - Wildfire Berkeley defensible space and home hardening checklist.



Most of the hazard mitigation is elective.


6 | Performance Requirements

Main driver of

envelope upgrades

- 6.1 Simulation General Requirements
- 6.2 Winter Resilience
- 6.3 Summer Resilience
- 6.4 Life Cycle Cost and Impact Control
 - 6.4.1 ADORB / FCALC Cost Limit
 - 6.4.2 Additional Decarbonization Effort

6.1 | Stress Weather for Resilience Tests





6.3 | Summer Resilience

- Zero hours of Heat Index in Danger
- Limited hours of Heat Index in Extreme Caution

Probably requires at least two simulation passes, to try different operation modes, e.g.

- Passive window shades, window night flush, evaporative cooling
- Add or substitute active daytime PV-powered mechanical cooling



7 | Monitoring Requirements

Minimum requirements

- Track energy use in Energy Star Portfolio Manager
- Report to authority
- 7.1 Indoor Environment Monitoring Electives
- 7.2 Energy End-Use Monitoring Elective
- 7.3 Water Quality Monitoring Elective
- 7.4 Waste/Materials Tracking Elective



6.4 | ADORB / FCALC

Direct cost categories, for planning & reporting

Performance related

- Envelope
 - Air leakage / sealing / tightness
 - Ceilings, Roofs
 - Walls
 - Foundation, Floors
- HVAC
 - Mechanical ventilation
 - Space Conditioning
- Hot Water (DHW, SHW)
- Major appliances
- Lighting
- PV / Battery / Generation
- Other performance-related

Not performance related

- Indoor air quality related
- Hazard mitigation related
- Other in-scope
- Other out-of-scope
- Incentives
- Tax credits

Carbon accounting concepts

The boundary in space encompasses the whole world supply chain.

The boundary in time:

- Extends into the future through the life of the building.
- Does **not** extend indefinitely into the past, i.e., to carbon sequestration done by trees decades ago.
 - We are not counting the emissions from making the original building decades ago...
 - Nor the original emissions from steel that we are recycling...



Embodied carbon: Level 1 embodied carbon calculation

Economic input-output based

- Cost of materials and labor, including soft costs
- Country of origin for materials



Embodied carbon: Level 1 embodied carbon calculation

Economic input-output based

- Cost of materials and labor, including soft costs
- Country of origin for materials

| Country | US Trading Rank | GDP [USD MM] | CO ₂ [MT] | EF [kg/\$] |
|---------|-----------------------|-----------------|-------------------------|----------------------|
| USA | - | 20,936,600.00 | 4,900.0 | 0.234 |
| China | 1 | 14,722,730.70 | 9,500.0 | 0.645 |
| Canada | 3 | 1,643,407.98 | 565.2 | 0.344 |
| Germany | 5 | 3,806,060.14 | 696.1 | 0.183 |
| India | 10 | 2,622,983.73 | 2,300.0 | 0.877 |
| France | 15 | 2,603,004.40 | 303.5 | 0.117 |



Embodied carbon: Level 1 embodied carbon calculation

For a \$1,000 Import from Canada: \$1,000 × 0.344 kg/\$ = 344 kg CO₂e 344 kg × \$0.25/kg = \$86 embodied carbon cost

6% consulting fees on a \$1,000,000 project: \$60,000 × 0.234 × 0.25 **= \$3,510**

| Country | US Trading Rank | GDP [USD MM] | CO ₂ [MT] | EF [kg/\$] |
|---------|-----------------------|-----------------|-------------------------|----------------------|
| USA | - | 20,936,600.00 | 4,900.0 | 0.234 |
| China | 1 | 14,722,730.70 | 9,500.0 | 0.645 |
| Canada | 3 | 1,643,407.98 | 565.2 | 0.344 |
| Germany | 5 | 3,806,060.14 | 696.1 | 0.183 |
| India | 10 | 2,622,983.73 | 2,300.0 | 0.877 |
| France | 15 | 2,603,004.40 | 303.5 | 0.117 |



Embodied carbon: Level 2 embodied carbon calc

A correction to Level 1 rather than a replacement of it.

Credits for carbon reductions available from 3 kinds of measures:

- Material choices
- Business practices
- Personal choices
 - Apply in the years worked on the project, adjusted based on % of income from project.


Reductions are relative to measure-specific baselines.



Operational carbon - emission rates for electricity used


<u>Time resolution</u> - hourly (or annual) <u>Spatial resolution</u> - GEA regions (similar to Egrid) <u>Protocol</u> - NREL Cambium Levelized LRMER with

- Emission CO₂e
- Emission stage Combined
- Start year 2023
- Evaluation period 70 years
- Discount rate (real) 0
- Scenario 95% decarb by 2050
- Global Warming Potentials 100-year (AR5)
- Location End-use



6.4.1 | Life Cycle Cost Limit

 The ADORB / FCALC cost of the proposed retrofit is to be no greater than that of a baseline case, in which the building is operated and maintained as-is.





6.4.2 | Additional Decarbonization Effort

Operational — Do one of the following:

- a. Electrify in the 1st implementation phase and use onsite and offsite renewables per Phius Zero (see Appendix A of Certification Guidebook.)
- b. From the 1st implementation phase onward, subscribe to community solar at 100% of predicted post-retrofit energy use.
 - * Elective community scale storage or full-on microgrid.

Embodied — Do at least one Level 2 embodied carbon measure.



Additional decarbonization effort

Operational — Do one of the following:

The ADORB cost limit may motivate this well enough on its own.

- a. Electrify in the 1st implementation phase and use onsite and offsite renewables per Phius Zero (see Appendix A of Certification Guidebook.)
- b. From the 1st implementation phase onward, By the final phase, subscribe to community solar at 100% of predicted post-retrofit energy use.

* *Elective* - *community* scale storage or full-on microgrid.

Embodied — Do at least one Level 2 embodied carbon measure.







1.1

To establish:

Requirements for retrofit improvement work on existing buildings.

Criteria for the selection of buildings for retrofit (as opposed to razing or replacement with new buildings.)



1.2

The purposes of the improvements are to:

Eliminate direct and indirect greenhouse gas emissions, in normal operation.

Provide resilience to winter and summer power outages.

Fix defects of concern to the US EPA, that pose risks to indoor air quality.

Where appropriate, fortify the building against certain site hazards of concern to US FEMA.

Meet specific owner's project requirements closely related to the above.



1.3

There are also process requirements:

For commissioning / quality assurance.

To calculate the climate impact of the retrofit work itself and make efforts to reduce it.

To collect data on project costs, post-retrofit performance, and lessons learned.


Let's take a break for more questions.

Next Up: Some sample calculations by Al

OModeling Overview

Developing a new tool to support these analyses:


- Hourly resilience simulation
- Hourly annual normal operation Simulation
- ADORB LCCA
- Future GUI Interface





US DOE Prototypical Single Family House:

- 2 Stories
- 3 beds (4 occ)
- 2,128 sqft (198 sqm)
- 13.5% WWR
- slab on grade



Packages and Summer Modes

Retrofit Packages:

- 0. Baseline House
- 1. Electrification
- 2. DOE 'Market Ready Envelope'
- 3. IECC 2021
- 3b. IECC 2021 @ 0.06cfm50
- 4. Phius CORE Prescriptive

Summer Modes:

NV - natural vent., temp control SNV - scheduled nat. vent., temp

ctrl.

SNV+Shd - add exterior blinds

HP - heat pump

HP+Shd - heat pump + ext. blinds

EC - evaporative cooler (B zones)

EC+Shd - evap cooler + ext. blinds



(Q) Chicago Cases Input Summary

| Package | Grid Region | Water Heater Fuel | Space Conditioning System | Flow Coefficient [SI] | Window U- Factor | Ext. Wall Type | Roof Type | Natural Ventilation Type |
|------------------------------------|-------------|----------------------|---------------------------------|-----------------------------|---------------------|-------------------------------|--------------------|--------------------------------|
| Pkg 0_Base House_NG | RFCWc | NaturalGas | GasFurnaceDXAC | 0.14849 | 0.47 | Exterior Wall | Exterior Roof | NatVent |
| Pkg 2_DOE Ready Envelope_NG | RFCWc | NaturalGas | GasFurnaceDXAC | 0.09292 | 0.36 | Exterior Wall +1.625in EPS | Exterior Roof R-60 | SchNatVent |
| Pkg 3_IECC 2021_NG | RFCWc | NaturalGas | GasFurnaceDXAC | 0.09292 | 0.3 | Exterior Wall +2in EPS | Exterior Roof R-60 | SchNatVent |
| Pkg 3B_IECC 2021 @ 0.06CFM50_NG | RFCWc | NaturalGas | GasFurnaceDXAC | 0.00695 | 0.3 | Exterior Wall +2in EPS | Exterior Roof R-60 | SchNatVent |
| Pkg 4_Phius Prescriptive_NG | RFCWc | NaturalGas | GasFurnaceDXAC | 0.00695 | 0.15 | Exterior Wall +6in EPS | Exterior Roof R-75 | SchNatVent |
| Pkg 0_Base House_E | RFCWc | Electricity | PTHP | 0.14849 | 0.47 | Exterior Wall | Exterior Roof | NatVent |
| Pkg 2_DOE Ready Envelope_E | RFCWc | Electricity | РТНР | 0.09292 | 0.36 | Exterior Wall +1.625in EPS | Exterior Roof R-60 | SchNatVent |
| Pkg 3_IECC 2021_E | RFCWc | Electricity | PTHP | 0.09292 | 0.3 | Exterior Wall +2in EPS | Exterior Roof R-60 | SchNatVent |
| Pkg 3B_IECC 2021 @ 0.06CFM50_E | RFCWc | Electricity | РТНР | 0.00695 | 0.3 | Exterior Wall +2in EPS | Exterior Roof R-60 | SchNatVent |
| Pkg 4_Phius Prescriptive_E | RFCWc | Electricity | PTHP | 0.00695 | 0.15 | Exterior Wall +6in EPS | Exterior Roof R-75 | SchNatVent |



Chicago Cases Output Summary


| Package | SET < 54°F [hr] | Hours < 35°F [hr] | Caution [hr] | Extreme Caution [hr] | Danger [hr] | Extreme Danger [hr] | EUI [kBtu / sf yr] | Peak Electric Demand [W] | Heating Battery Size [kWh] | Cooling Battery Size [kWh] | Total ADORB Cost [\$] |
|---------------------------------------|-----------------|----------------------|--------------|-------------------------|-------------|------------------------|-----------------------|-----------------------------|----------------------------------|----------------------------------|--------------------------|
| Pkg 0_Base House_E | 1019 | 119 | 66 | 58 | 0 | 0 | 38.7 | 20420 | 7.1 | 4.8 | \$200,889.44 |
| Pkg 2_DOE Ready Envelope_E | 556 | 53 | 60 | 65 | 0 | 0 | 27.8 | 13543 | 7.1 | 4.8 | \$169,735.37 |
| Pkg 3_IECC 2021_E | 504 | 41 | 62 | 63 | 0 | 0 | 26.9 | 13045 | 7.1 | 4.8 | \$165,994.31 |
| Pkg 0_Base House_NG | 1020 | 119 | 66 | 58 | 0 | 0 | 52.1 | 4488 | 7.1 | 4.8 | \$149,247.36 |
| Pkg 2_DOE Ready Envelope_NG | 557 | 53 | 60 | 65 | 0 | 0 | 35.5 | 3727 | 7.1 | 4.8 | \$144,998.14 |
| Pkg 3_IECC 2021_NG | 505 | 41 | 62 | 63 | 0 | 0 | 34.0 | 3645 | 7.1 | 4.8 | \$143,281.25 |
| Pkg 4_Phius Prescriptive_NG | 0 | 0 | 54 | 57 | 0 | 0 | 17.3 | 2359 | 7.1 | 4.8 | \$126,063.41 |
| Pkg 3B_IECC 2021 @ 0.06CFM50_E | 60 | 0 | 56 | 56 | 0 | 0 | 18.7 | 6863 | 7.1 | 4.8 | \$125,091.65 |
| Pkg 3B_IECC 2021 @ 0.06CFM50_NG | 61 | 0 | 56 | 56 | 0 | 0 | 22.3 | 2789 | 7.1 | 4.8 | \$124,416.52 |
| Pkg 4_Phius Prescriptive_E | 0 | 0 | 54 | 57 | 0 | 0 | 15.3 | 4889 | 7.1 | 4.8 | \$119,252.07 |




NYC Cases Output Summary

| | | Hours < 35°F [hr] | Caution [hr] | Extreme Caution [hr] | Danger [hr] | Extreme Danger [hr] | EUI [kBtu / sf yr] | Peak Electric Demand [W] | Heating Battery Size [kWh] | Cooling Battery Size [kWh] | Total ADORB Cost [\$] |
|---|-----|----------------------|--------------|-------------------------|-------------|------------------------|-----------------------|-----------------------------|----------------------------------|----------------------------------|--------------------------|
| NYC_JFK_Packa ge_0_BASE House_Elec | 350 | 10 | 71 | 10 | 0 | 0 | 31.8 | 13758 | 6.8 | 4.7 | \$145,801.47 |
| NYC_JFK_Packa ge_2_DOE Envelope Elec | 105 | 0 | 73 | 0 | 0 | 0 | 23.5 | 9175 | 6.8 | 4.7 | \$129,568.76 |
| NYC_JFK_Packa ge_3_IECC_Elec | 78 | 0 | 71 | 0 | 0 | 0 | | | 6.8 | 4.7 | |
| NYC_JFK_Packa ge_0_BASE House | 350 | 10 | 71 | 10 | 0 | 0 | 48.0 | 3013 | 6.8 | 4.7 | \$121,312.64 |
| NYC_JFK_Packa ge_2_DOE Envelope_NG | 105 | 0 | 73 | 0 | 0 | 0 | 33.8 | 2535 | 6.8 | 4.7 | \$121,228.07 |
| NYC_JFK_Packa ge_3_IECC_NG | 78 | 0 | 71 | 0 | 0 | 0 | 32.5 | 2486 | 6.8 | 4.7 | \$117,014.21 |
| NYC_JFK_Packa ge_4_Phius Retrofit_NG | 0 | 0 | 0 | 0 | 0 | 0 | 18.6 | 2020 | 6.8 | 4.7 | \$108,753.66 |
| NYC_JFK_Packa ge_3_IECC+Phiu s Airseal NG | 0 | 0 | 0 | 0 | 0 | 0 | 22.8 | 2217 | 6.8 | 4.7 | \$102,554.65 |
| NYC_JFK_Packa ge_4_Phius Retrofit_Elec | 0 | 0 | 0 | 0 | 0 | 0 | 14.5 | 4037 | 6.8 | 4.7 | \$99,849.41 |
| NYC_JFK_Packa ge_3_IECC+Phiu s Airseal_Elec | 0 | 0 | 0 | 0 | 0 | 0 | 16.9 | 5280 | 6.8 | 4.7 | \$97,444.34 |


ChicagoMDW_Package_0_BASE House_Elec_Heating Outage Resilience




ChicagoMDW_Package_2_DOE Envelope_Elec_Heating Outage Resilience




ChicagoMDW_Package_3_IECC_Elec_Heating Outage Resilience




ChicagoMDW_Package_3_IECC+Phius Airseal_Elec_Heating Outage Resilience




ChicagoMDW_Package_4_Phius Retrofit_NG_Heating Outage Resilience




ChicagoMDW_Package_0_BASE House_Cooling Outage Resilience




ChicagoMDW_Package_2_DOE Envelope_Elec_Cooling Outage Resilience




ChicagoMDW_Package_3_IECC_Elec_Cooling Outage Resilience



ChicagoMDW_Package_4_Phius Retrofit_Elec_Cooling Outage Resilience




ChicagoMDW_Package_3_IECC+Phius Airseal_NG_Cooling Outage Resilience






Chicago ADORB Cost






NYC ADORB Cost





Nashville ADORB Cost



Evolution / Improvement Opportunities

- How tight is the bind, between enough for resilience and too much life cycle cost? Stringency adjustment (discount rate on carbon?)
- Stress weather for resilience tie to future climate models a la Sandia MEWS.
- Human exposure models other than Heat Index.
- Adding parametric / parallel coordinate / optimization wrapped around the single-case calculation engine.
- Add calculation methods for new resilience measures.
- Derivation of more prescriptive guidance from parametric results.
- More localism microgrids, local spare parts and servicepeople.
- Turn some electives into mandatory.

Within a few weeks, we expect:

- Publication and a call for public comment
- A call for participation in our open-source software development



Thank you!

DAUS COR HOUSTON 2023

Tuesday 11/7 - Friday 11/10

Call for Abstracts NOW OPEN!

Link to submit presentation proposals for PhiusCon 2023 will be sent via email tomorrow

Conference Registration Coming Soon!

- Early bird registration will be opening in the next several weeks
- Follow our social media channels for the latest updates!