

Edgewood and Emerald Hills

Post Occupancy Performance Analysis



phius con

MILWAUKEE 2025

Objectives

- Our intent is to convey some of the information learned about two different system types in Passive Building projects
- We hope that our experience will help you to evaluate system options for future projects
- You will also gain understanding of some of the issues that can cause buildings to use more energy than modeling predicts

Outline

Emerald Hills

- Building and systems description
- Measured energy consumption versus modeled
- Discussion of discrepancies
- Discussion of construction related issues for Emerald systems

Edgewood

- Building and systems description
- Measured energy consumption versus modeled
- Discussion of discrepancies
- Discussion of construction related issues for Edgewood systems
- Investigation of larger than expected energy consumption for Edgewood
- Discussion of systems comparison


Emerald Hills




Location	Size	Population	Envelope	HVAC	Ventilation	HW System	Solar	Occupied
Pittsburgh	55 Apartments	Senior Housing	Walls: R37 Roof: R53 Windows: 3-pane	Ducted - Split Heat Pumps	Semi-Central ERVs	Condensing Gas	116 kW Solar Array feeds House Panel	Spring 2022

Emerald Hills

- One-one heat pumps (cold climate)
- Neighborhood ERVs
- Gas – Central HW Heaters



Emerald Hills



Compact
Ductwork
Design




Neighborhood
ERVs

Emerald Hills - DHW

- Domestic HW generated by condensing gas HW heaters.
- Three 199,000 BTU/hr sealed combustion heaters.



Results



Energy Performance

Weather Corrected Models:

- WUFI model low on cooling and lighting compared to IES model.
- IES model likely low on HVAC due to less than optimal COP
- Domestic HW energy right in line with models
- Removed solar production from analysis


EUI = 21.97

EUI = 26.69

EUI = 30.57

EUI = 23.29

Modeled vs. Measured Performance



Results

- Emerald Hills ERV fan energy modeled vs actual (estimate).

Emerald Hills Engineering Checks

By: G. Staengl J. Nilsen

Date: 8/19/2022

ERV	Measured Power [W]	Corrected Power Draw [W]	Design Supply Flow [CFM]	W/CFM
1-5	236	200	355	0.6
1-3	570	534	270	2.0
1-4	50	14	230	0.1
1-6	630	594	360	1.7
1-7	440	404	485	0.8
1-8	280	244	360	0.7
1-9	460	424	435	1.0
2-1	290	254	550	0.5
2-2	450	414	640	0.6
		3082	3685	0.836


Modeled ERV Fan Energy: 109,000 kBTU/yr


Calculated ERV Fan Energy: 92,145 kBTU/yr

Actual ERV energy likely larger because power draw goes up as the filters get dirty.



Results





Emerald

Year: 2020

Senior Affordable Housing Apartments 52 total

Occupancy: R-2

Construction Type: VB

Sprinkler: NFPA 13R

floor rating : 1 hour

Square footage


First Floor	14,733 sq. ft.
Second Floor	14,501 sq. ft.
Third Floor	14,345 sq. ft.
Fourth Floor	14,345 sq. ft.
Total	57,924 sq. ft.

Floor to Floor Heights:

1st to 2nd : 11'-5"

2nd to 3rd : 10'-6"


3rd to 4th : 10'-6"




Edgewood



Location	Size	Population	Envelope	HVAC	Ventilation	HW System	Occupied
Pittsburgh	55 Apartments	Senior Housing	Walls: R37 Roof: R53 Windows: 2-pane	EPHOCA All-In-One units	EPHOCA All-In-One units	CO2 Heat Pumps	Spring 2024





Edgewood




EPHOCA™ AIO (ALL IN ONE) Heat Pump + ERV

- Heat Pump and ERV combined
- Fresh air is drawn out of the condenser air stream
- Exhaust air is pushed into condenser air exhaust
- ECM fans all around
- Inverter driven compressor



Condenser Air

Code issue forces louver because of built-in ERV.



1300 FPM at Max Flow

We typically size louvers at below 700 fpm (less for intake).



Domestic HW



Results


- WUFI model low on cooling and lighting compared to IES model.
- IES model likely low on HVAC due to less than optimal COP?

EUI = 15.19


EUI = 20.96

EUI = 25.78

Modeled vs. Measured Performance




Comparisons




Comparisons - House

- Gas hot water amplifies Emerald Hills site energy (no COP)
- Neighborhood ERVs on house meter




Comparisons - House

- Corrected with ERV energy and assumed COP of 3 for DHW




Comparisons - Apartments

- Why is apartment energy higher at Edgewood?



Comparisons - Apartments

- Corrected for ERVs
- Emerald Hills:
 - One Bedroom:
672 sqft
 - Two Bedroom
934 sqft
- Edgewood
 - One Bedroom:
694 sqft (3% larger)
 - Two Bedroom
976 sqft (5% larger)



Investigation



Edgewood Ephoca Testing

UNIT 105

Outdoor Temp 44 F

Cooling - High

Setpoint	66 F
Return Air Temp	74 F
Supply Air Temp	48.5 F
Bedroom Airflow	95 CFM
Living Room Airflow	140 CFM
Return Airflow	CFM
Current Draw	2.9 A
Voltage*	208 V
Watts	603.2 W
Output	6472 BTU/hr
COP	4.558

Cooling - Medium

Setpoint	65 F
Return Air Temp	72 F
Supply Air Temp	45 F
Bedroom Airflow	75 CFM
Living Room Airflow	115 CFM
Return Airflow	CFM
Current Draw	2.33 A
Voltage*	208 V
Watts	484.6 W
Output	5540 BTU/hr
COP	5.458

Cooling - Low

Setpoint	65 F
Return Air Temp	72 F
Supply Air Temp	42 F
Bedroom Airflow	59 CFM
Living Room Airflow	98 CFM
Return Airflow	CFM
Current Draw	1.8 A
Voltage	208 V
Watts	374.4 W
Output	5086.8 BTU/hr
COP	7.96164

Heating - High

Setpoint	75 F
Return Air Temp	73 F
Supply Air Temp	94.5 F
Bedroom Airflow	90 CFM
Living Room Airflow	135 CFM
Return Airflow	CFM
Current Draw	3.5 A
Voltage	208 V
Watts	728 W
Output	-5225 BTU/hr
COP	-2.83

Heating - Medium

Setpoint	83 F
Return Air Temp	72 F
Supply Air Temp	93 F
Bedroom Airflow	76 CFM
Living Room Airflow	106 CFM
Return Airflow	CFM
Current Draw	3.1 A
Voltage	208 V
Watts	644.8 W
Output	-4128 BTU/hr
COP	-2.64

Heating - Low

Setpoint	83 F
Return Air Temp	72 F
Supply Air Temp	93.9 F
Bedroom Airflow	55 CFM
Living Room Airflow	84 CFM
Return Airflow	CFM
Current Draw	2.1 A
Voltage	208 V
Watts	436.8 W
Output	-3287.6 BTU/hr
COP	-3.8592



Ventilation Only

Current Draw	0.9 A
Voltage	208 V
Watts	187.2 W
Bathroom Airflow	25 CFM
Kitchen Airflow	25 CFM
Bedroom Airflow	23 CFM
Living Room Airflow	25 CFM


3.75 W/cfm!

EPHOCA™ AIO (ALL IN ONE) Heat Pump + ERV

- Heat Pump and ERV combined
- Fresh air is drawn out of the condenser air stream
- Exhaust air is pushed into condenser air exhaust
- ECM fans all around
- Inverter driven compressor



Investigation



Investigation Results


- EPHOCA has made a programming change to reduce fan energy when there is not heating or cooling required. This is being rolled out at Edgewood.
- Some units have been found to have restrictions in the return air pathway, which may be leading to increased indoor fan energy and decreased efficiency.
- Construction debris was left in coils which likely reduced efficiency during the first winter season. Coils have been cleaned and are on a regular maintenance schedule.

EPHOCA Updated Programming Results

Old Firmware 2.0 version		
Fan speed Setting	Input / Heating mode comp	Input / Cooling mode comp
	off / ERV 50CFM	off / ERV 50CFM
V1	95,5 watt	93,3 watt
V2	172 watt	168,7 watt
V3	240 watt	240 watt
Auto	96,3 watt	94,5 watt
New Firmware 3.0 version		
Fan speed Setting	Input / Heating mode comp	Input / Cooling mode comp
	off / ERV 50CFM	off / ERV 50CFM
V1	31,3 watt	35,9 watt
V2	31,5 watt	38,5 watt
V3	31,7 watt	38,7 watt
Auto	32,1 watt	37,5 watt

Data provided by EPHOCA





Edgewood

Senior Affordable Housing Apartments 52 total

Occupancy: R-2

Construction Type: VB

Sprinkler: NFPA 13R

Square footage

First Floor 16,347 sq. ft.

Second Floor 15,547 sq. ft.

Third Floor 15,547 sq. ft.

Fourth Floor 15,547 sq. ft.




Total 72,988 sq. ft.

Floor to Floor Heights:

1st to 2nd : 11'-5"

2nd to 3rd : 11'-8"

3rd to 4th : 10'-6"



Owner's Perspective



System type comparison

Strategy	Ductwork	Penetrations	Install difficulty
Emerald Hills (ducted splits with neighborhood ERVs)	More ductwork	Less penetrations . Façade coordination	More challenging due to coordination with ceilings / structure <ul style="list-style-type: none">• Need slim vertical form factor• Site installed refrigeration line-sets• Location of ERVs and outdoor condensers
Edgewood (All-in-one)	Much less ductwork, could be even less.	Much more penetrations	More elegant, but need larger intake louver by manufacturer



System type comparison

Strategy	Cost	Equipment Support	Manufacturer Responsiveness	System Complexity
Emerald Hills (ducted splits with neighborhood ERVs)	Lower equipment cost Higher labor cost	Good	Slow – but product is mature and well supported	Separate systems are easier to design and commission because of industry experience
Edgewood (All-in-one)	Higher equipment cost Lower labor cost	Good	Fast	All-in-one is a simpler install, but understand of operation and efficiency is immature <ul style="list-style-type: none"> - Efficiency standard does not exist yet - Ventilation is integrated, and thus more complex to diagnose and verify



System type comparison

Strategy	Maintenance Required
Emerald Hills (ducted splits with neighborhood ERVs)	Moderate
Edgewood (All-in-one)	Higher - Condenser coil cleaning requires removal of cabinet panels

[Cleaning Video](#)

		EMERALD	EDGEWOOD	DIFFERENCE
Filters		\$ 1,259.35	\$ 1,950.00	\$ 690.65
Coil Cleaning		\$ 1,081.88	\$ 4,000.00	\$ 2,918.12
Maintenance Contract		\$ 5,272.96	\$ 6,231.86	\$ 958.90
TOTAL		\$ 7,614.19	\$ 12,181.86	\$ 4,567.67



Thank You!



Rick Avon, AIA, CPHC, Reset Air AP
www.avondg.com
info@avondg.com
(412) 366-0222



Victor Rodriguez
www.cmshousing.com
v.rodriguez@cmshousing.com
(412)231-3621



Galen Staengl, PE, CPHC, LEED AP
Devin Wright, PE
www.staenglengineering.com
gstaengl@staenglengineering.com
(434)295-8105

